

## Identification Letters

FIRST-LETTER (4)		SUCCEEDING-LETTERS (3)		
MEASURED OR INITIATING VARIABLE	MODIFIER	READOUT OR PASSIVE FUNCTION	OUTPUT FUNCTION	MODIFIER
A	Analysis		Alarm	
B	Burner, Combustion		User's Choice	User's Choice
C	User's Choice			Control
D	User's Choice	Differential		
E	Voltage		Sensor (Primary Element)	
F	Flow Rate	Ratio (Fraction)		
G	User's Choice		Glass, Viewing Device	
H	Hand			High
I	Current (Electrical)		Indicate	
J	Power	Scan		
K	Time, Time Schedule	Time Rate of Change		Control Station
L	Level		Light	Low
M	User's Choice	Momentary		Middle, Intermediate
N	User's Choice		User's Choice	User's Choice
O	User's Choice		Orifice, Restriction	
P	Pressure, Vacuum		Point (Test) Connection	
Q	Quantity	Integrate, Totalize		
R	Radiation		Record	
S	Speed, Frequency	Safety		Switch
T	Temperature			Transmit
U	Multivariable		Multifunction	Multifunction
V	Vibration, Mechanical Analysis			Valve, Damper, Louver
W	Weight, Force		Well	
X	Unclassified	X Axis	Unclassified	Unclassified
Y	Event, State or Presence	Y Axis		Relay, Compute, Convert
Z	Position, Dimension	Z Axis		Driver, Actuator, Unclassified Final Control Element